

AUTOMATIC TRANSFER SWITCH DATA SHEET
(ATS)

DATE : 10/25/2023
CUSTOMER : HVES
SUBSTATION : Switch 19
SWITCH ID : ATS
MFR. : Generac
M/N or Type : GTS-1600
S/N : 72120

FRAME SIZE : 1600A (D)
SENSOR TAP : 1600A
CONTROL TYPE
GROUP : GJS-1600
PHASE : THREE
WIRE : 4 pole
S/N :

VISUAL INSPECTION

Contact Visual : SATISFACTORY
Operations : SATISFACTORY
Controls : SATISFACTORY

TRANSFER TESTS

Service 1 : Bus 1 CPT
Service 2 : Bus 2 CPT

Transfer	: Bus 1	to: Bus 2	: SATISFACTORY
Return	: Bus 1 Normal	to: Bus Standby	: SATISFACTORY

COMMENTS:

480V, 60Hz, 4-Pole
Tag #11522

10/25/2023 Performed transfer test Bus 1 to Bus 2 and returned operated Bus 1 Normal to Bus Standby. All transfer tests were satisfactory.



GENERAC

DANGER
HIGH VOLTAGE
KEEP OUT

Little Giant KING KOMBI